Fire extinguisher monthly check

A quick visual check by your responsible person between yearly services by a competent engineer.

Site		**Asset / ID**	
Date		**Time**	
Checked by		**Signature**	

#	Check	Pass	Fail	Notes
1	In its correct place, mounted or on a stand			
2	Clearly visible, signed and not blocked			
3	Safety pin and tamper seal in place			
4	Pressure gauge in the green (where fitted)			
5	No damage, dents, rust or leaks			
6	Hose and horn not cracked or blocked			
7	Operating instructions readable			
8	Service label shows a service in the last 12 months			

Defects found and action taken:

Tag every extinguisher with Checkmate and see at a glance which are checked. Free for 2 weeks.
Book your free demo: checkmate-uk.co.uk · 07882 236560

These are general checklists. Always follow the manufacturer's instructions and your own risk assessment, and adapt the items to your equipment. They don't replace expert inspections required by law or guidance, such as LOLER thorough examinations or annual racking inspections.